



# 單乙閥濾水清洗步驟

## 濾水器


(0) A. 過濾



(1) B. 逆洗 (3-10分)



(2) E. 排清 (1-5分)



### 【濾水清洗步驟】

(0) A. 過濾 →

(1) 關閉出水口 →

B. 逆洗(3-10分鐘) →

(2) E. 排清(1-5分)

平時轉至過濾位置, 約7至15天操作清洗步驟一次(視水質而有所不同)



1A00001A